Energy Performance Certificate (EPC)

Dwellings

(1-20)

Scotland

23 LABRADOR AVENUE, HOWDEN, LIVINGSTON, EH54 6BU

Dwelling type:Mid-terrace houseDate of assessment:26 September 2024Date of certificate:26 September 2024

Total floor area: 73 m²

Primary Energy Indicator: 309 kWh/m²/year

Reference number: 0100-2986-4110-2324-8061
Type of assessment: RdSAP, existing dwelling

Approved Organisation: Elmhurst

Main heating and fuel: Warm air, mains gas


You can use this document to:

· Compare current ratings of properties to see which are more energy efficient and environmentally friendly

· Find out how to save energy and money and also reduce CO2 emissions by improving your home

Estimated energy costs for your home for 3 years*	£5,391	See your recommendations
Over 3 years you could save*	£2,211	report for more information

^{*} based upon the cost of energy for heating, hot water, lighting and ventilation, calculated using standard assumptions



Potential Current Very environmentally friendly - lower CO2 emissions (92 plus) (81-91) B 86 (68-80) C 55:881 D 59 (39-54 巨 (21-38) 屋

G

Energy Efficiency Rating

This graph shows the current efficiency of your home, taking into account both energy efficiency and fuel costs. The higher this rating, the lower your fuel bills are likely to be.

Your current rating is **band D** (57). The average rating for EPCs in Scotland is **band D** (61).

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

Environmental Impact (CO₂) Rating

This graph shows the effect of your home on the environment in terms of carbon dioxide (CO_2) emissions. The higher the rating, the less impact it has on the environment.

Your current rating is **band D** (59). The average rating for EPCs in Scotland is **band D** (59).

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

Top actions you can take to save money and make your home more efficient

Recommended measures	Indicative cost	Typical savings over 3 years
1 Floor insulation (suspended floor)	£800 - £1,200	£372.00
2 Increase hot water cylinder insulation	£15 - £30	£510.00
3 Low energy lighting	£25	£96.00

A full list of recommended improvement measures for your home, together with more information on potential cost and savings and advice to help you carry out improvements can be found in your recommendations report.

To find out more about the recommended measures and other actions you could take today to stop wasting energy and money, visit greenerscotland.org or contact Home Energy Scotland on 0808 808 2282.

Not environmentally friendly - higher CO2 emissions

THIS PAGE IS THE ENERGY PERFORMANCE CERTIFICATE WHICH MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED CERTIFICATE